

State of California  
AIR RESOURCES BOARD  
Executive Order DG-032  
Distributed Generation Certification of  
Capstone Turbine Corporation  
CR200 Low Btu MicroTurbine

WHEREAS, the Air Resources Board (ARB) was given the authority under California Health and Safety Code section 41514.9 to establish a statewide Distributed Generation (DG) Certification Program to certify electrical generation technologies that are exempt from the permit requirements of air pollution control or air quality management districts;

WHEREAS, this DG Certification does not constitute an air pollution permit or eliminate the responsibility of the end user to comply with all federal, state, and local laws, rules and regulations;

WHEREAS, on January 28, 2010, Capstone Turbine Corporation applied for a DG Certification of its 200 kW, CR200 Low Btu MicroTurbine and whose application was deemed complete on March 17, 2010;

WHEREAS, Capstone Turbine Corporation has demonstrated, according to test methods specified in title 17, California Code of Regulations (CCR), section 94207, that its digester gas fueled CR200 Low Btu MicroTurbine has complied with the following emission standards:

1. Emissions of oxides of nitrogen no greater than 0.5 pounds per megawatt-hour;
2. Emissions of carbon monoxide no greater than 6.0 pounds per megawatt-hour; and
3. Emissions of volatile organic compounds no greater than 1.0 pounds per megawatt-hour;

WHEREAS, Capstone Turbine Corporation has demonstrated that its CR200 Low Btu MicroTurbine complies with the emissions durability requirements in title 17, CCR, section 94203 (d);

WHEREAS, I find that the Applicant, Capstone Turbine Corporation, has met the requirements specified in article 3, title 17, CCR, and has satisfactorily demonstrated that the CR200 Low Btu MicroTurbine meets the DG Certification Regulation 2008 Waste Gas Emission Standards;

NOW THEREFORE, IT IS HEREBY ORDERED, that a DG Certification, Executive Order DG-032 is granted.

This DG Certification:

- 1) is subject to all conditions and requirements of the ARB's DG Certification Program, article 3, title 17, CCR, including the provisions relating to inspection, denial, suspension, and revocation;
- 2) shall be void if any manufacturer's modification results in an increase in emissions or changes the efficiency or operating conditions of a model, such that the model no longer meets the DG Certification Regulation 2008 Waste Gas Emission Standards;
- 3) shall expire on the 26<sup>th</sup> day of August, 2015.

Executed at Sacramento, California, this 26<sup>th</sup> day of August 2010.

James Goldstene  
Executive Officer  
by

/S/

Richard Corey, Chief  
Stationary Source Division